

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 69796  
 Permit No. \_\_\_\_\_  
 Basin 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36408

1. OWNER AMADEO BOADELLA ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2135 GREENLEAF LANE #4 244 LEWIS LANE  
FALLON, NV 89407

2. LOCATION SE 1/4 NW 1/4 Sec. 28 T 19 N/S R 28 E CHURCHILL County  
 PERMIT NO. 00849355 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN SAND		0	15	15
BROWN CLAY		15	18	3
BROWN SAND		18	30	12
GREY SAND		30	40	10
BLACK SILT/CLAY		40	50	10
GREY SAND		50	60	10
GREY CLAY		60	64	4
BROWN SAND	X	64	77	13

8. WELL CONSTRUCTION  
 Depth Drilled 77 Feet Depth Cased 77 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4	Inches 0	Feet 50
6 1/8	Inches 50	Feet 77

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	77

Perforations:  
 Type perforation MACHINE SLOT  
 Size perforation .080

From 70 feet to 75 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement *Boade*  
 Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 10/13/97, 19\_\_\_\_  
 Date completed 10/13/97, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 hr.

9. WATER LEVEL  
 Static water level 10.4 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Welsco Drilling Corp. Contractor  
 Address 305 E. WILLIAMS AVE. P. O. BOX 888 Contractor  
FALLON, NV 89407  
 Nevada contractor's license number issued by the State Contractor's Board 11752  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996  
 Signed *[Signature]* By driller performing actual drilling on-site or contractor  
 Date 10/26/97