

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 69798  
 Permit No. \_\_\_\_\_  
 Basin 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36379

1. OWNER CAROL COLIP ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 255 DRUMM LANE 255 DRUMM LANE  
FALLON, NV 89406  
 2. LOCATION SE 1/4 SW 1/4 Sec. 6 T 18 N/S R 29 E CHURCHILL County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN SAND		0	121	121
BROWN CLAY		16	20	4
BROWN SAND		20	31	11
GREY SAND		31	60	29
BLACK SILT		60	90	30
GREY SAND		90	108	18
GREY CLAY		108	110	2
BROWN SAND	X	110	121	11

8. WELL CONSTRUCTION  
 Depth Drilled 121 Feet Depth Cased 121 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 3/4 Inches 0 Feet 50 Feet  
6 1/8 Inches 50 Feet 121 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	121

Perforations:  
 Type perforation MACHINE SLOT  
 Size perforation .080  
 From 115 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement Benite  
 Depth of Seal 50  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 8.4 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Welsco Drilling Corp. Contractor  
 Address 305 E. WILLIAMS AVE. P. O. BOX 888 Contractor  
FALLON, NV 89407  
 Nevada contractor's license number issued by the State Contractor's Board 11752  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996  
 Signed [Signature] By driller performing actual drilling on-site or contractor  
 Date 10-26-97

Date started 9/1/97, 19\_\_\_\_  
 Date completed 10/1/97, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>		<u>1 hr.</u>