WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 69826
Permit No.
Basin 105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 27137

1. OWNER Robert Leonard
MAILING ADDRESS 1385 Arizona Ave Milpitas Calif 95035
ADDRESS AT WELL LOCATION 18 17 Island Rd. Spring Valley Gardnerville Nev.

2. LOCATION NE ¼ NW ¼ Sec. 35 T. 11 N/S R. 21 E. Douglas County
PERMIT NO. ____ Issued by Water Resources | 35-252-32 Parcel No. | Spring Valley No. 1 Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
small rock in brown clay		5	15	10
sandy clay brown		15	75	60
gravel	yes	75	93	18
gravel + sandy brown clay		95	125	30
gravel + sand with small brown clay strata		125	138	13
gravel sand + clay	yes	138	165	27

Date started Dec 8, 1997
Date completed Dec 26, 1997

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	18	10 ft	3 hrs

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 8 inches Total depth 160 feet
____ inches
____ inches
Casing record
Weight per foot ____ Thickness 188

Diameter	From	To
8 inches	0 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement grout
Depth of seal 50 ft feet
Gravel packed: Yes ☐ No ☑
Gravel packed from ____ feet to ____ feet

Perforations:
Type perforation factory
Size perforation 3/32 + 3
From 120 feet to 160 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 65 feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Contractor
Address P.O. Box 97 Contractor
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada contractor's driller's number issued by the Division of Water Resources 718
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller
By driller performing actual drilling on site or contractor
Date Dec 27 97

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627