

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 69831
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17321

OWNER Marianna & Manfred Becker ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 5890 E. Kent 5890 E. Kent
Pahrump, NV 89048
 2. LOCATION SE 1/4 SE 1/4 Sec. 16 T 21S N/S R 54E E Nye County
 PERMIT NO. 45-151-04 Kellogg Hillside Estates
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN CALCHE		0	15	15
See next line		15	32	17
BROWN CALACHE & GRAVEL & ROCK				
LIGHT BROWN CALACHE & ROCK		32	47	15
LIGHT BROWN CALACHE & GRAVEL		47	68	21
RED BROWN CALACHE AND ROCK		68	89	21
BROWN CALACHE AND GRAVEL		89	115	26
BROWN CALCHE & ROCK & GRAVEL		115	142	27
See next line	X	142	165	23
REDISH BROWN CALACHE & ROCK & GRAVEL				
RED BROWN & GRAVEL & ROCK		165	180	15

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 7/8 Inches 0 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	180

Perforations:
 Type perforation Saw Cut
 Size perforation .188
 From 140 feet to 180 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 180 feet



9. WATER LEVEL
 Static water level 115 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
 Signed Randy Strickland
 By driller performing actual drilling on-site or contractor
 Date 1.14.98

Date started 1/10/98, 19____
 Date completed 1/10/98, 19____

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>.5</u>	<u>na</u>	<u>.50</u>	



KC