WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69834
Permit No.
Basin 162

NOTICE OF INTENT NO. 17320

OWNER Joseph and Susan Vallone
MAILING ADDRESS 3561 Stirrup Ave.
Pahrump, NV 89048

ADDRESS AT WELL LOCATION 3561 Stirrup Ave.

2. LOCATION NE 1/4 SE 1/4 Sec. 34 T 20S N/S R 53E E Nye County
PERMIT NO. (Issued by Water Resources) 40-683-02 (Parcel No.) Calvada Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DARK BROWN CLAY		0	4	4
BROWN CLAY		4	12	8
GREY CLAY		12	16	4
BROWN CLAY		16	30	14
BROWN CLAY		30	45	15
LIGHT BROWN CLAY		45	65	20
LIGHT BROWN CLAY	X	65	79	14
LIGHT BROWN CLAY	X	79	90	11
BROWN CLAY	X	90	109	19
BROWN CLAY	X	109	132	23
BROWN CLAY	X	132	145	13

Date started 1/8/98, 19__
Date completed 1/8/98, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
.5	na	.50

8. WELL CONSTRUCTION
Depth Drilled 145 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 7/8	Inches	0	Feet	145	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	145

Perforations:
Type perforation Saw Cut
Size perforation .188
From 110 feet to 145 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 145 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. (Contractor)
Address 2301 Winery Road, Suite 2 (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed [signature] (By driller performing actual drilling on-site of contractor)
Date 1-14-98

DWR JAN 1998 LAS VEGAS OFFICE

KC