

OFFICE USE ONLY
 Log No. 69841
 Permit No. 105
 Basin. _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28057

1. OWNER Paul Richette ADDRESS AT WELL LOCATION 632 ThoroBred Gardnerville NV. 89410
 MAILING ADDRESS _____

2. LOCATION NE 1/4 NE 1/4 Sec 25 T. 12 N. R. 20 E. Douglas County
 PERMIT NO. 29-102-04 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
overburden		0	3	3
Cobbles w/ tabbed Gravels		3	208	205
Obsidian Cobbles fractured gravel zones		208	127	59
Hard Slate (fractured)		127	193	66
Hard Fractured obsidian dacitic Gravels		193	210	17
Brown Sandy Clay		210	230	20
Fractures w/ water Cobbles w/ clay seams	XX	230	260	30

8. WELL CONSTRUCTION
 Depth Drilled 260 Feet Depth Cased 260 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 260 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/8 10 3/8	13.03	.188	0	260

Perforations:
 Type perforation Mill Slot
 Size perforation 3 x 3/8
 From 240 feet to 260 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 30 feet to 260 feet

9. WATER LEVEL
 Static water level 140 feet below land surface
 Artesian flow _____ G.P.M. 18-19 P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Capital City Well drilling Contractor
 Address 20 Kit Kat Dr. Carson City NV. 89706 Contractor
 Nevada contractor's license number 41775 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael Black
 By driller performing actual drilling on site or contractor
 Date 11-14-97

Date started 11-6 1997
 Date completed 11-13 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>18-19</u>	<u>45</u>	<u>3 HRS</u>

RECEIVED
 97 NOV 18 AM 10:10
 STATE ENGINEER'S OFFICE