

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 69845
 Permit No. 162
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17336

OWNER Jeff Jones ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2831 E Falcon 2831 E Falcon
Pahrump, NV 89048
 2. LOCATION SE 1/4 SE 1/4 Sec. 36 T 20S N/S R 53E E Nye County
 PERMIT NO. 41-222-25 Calvada Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown sandy loam		0	12	12
grey clay		12	16	4
grey calache		16	30	14
grey calache		30	45	15
light brown calache		45	65	20
brown clay	x	65	79	14
brown calache	x	79	96	17
brown calache/clay mix	x	96	123	27
brown calache/clay mix	x	123	140	17

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 7/8 inches 0 Feet 140 Feet
 _____ inches _____ Feet _____ Feet
 _____ inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation Saw Cut
 Size perforation .188
 From 110 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet



9. WATER LEVEL
 Static water level 65 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
 Signed Randy Strickland
 By driller performing actual drilling on-site or contractor
 Date 1-20-98

Date started 1/16/98 19____
 Date completed 1/16/98 19____

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.		
<u>.5</u>	<u>na</u>	<u>.50</u>



KC