WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69988
Permit No.
Basin 230

NOTICE OF INTENT NO. 16929

1. OWNER Jim + Alice Donaldson
MAILING ADDRESS HCR 69 Box 4970
Amargosa Valley, NV 89020

ADDRESS AT WELL LOCATION Approx 600' S
Amargosa Farm Rd + Lewis St
Amargosa Valley, NV 89020

2. LOCATION NE ¼ NW ¼ Sec. 15 T 16S N/S R 48 E MDBM Nye County
PERMIT NO. NA Issued by Water Resources
41-019-551-59 Parcel No.
— Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Sand		0	5	5
Caliche		5	17	12
Sand - Fine Gravel		17	45	28
Sand - Gravel to ½"		45	50	5
Sand - Clay		50	95	45
Sand - Hard		95	105	10
Sand - Clay - Gravel	W	105	113	8
Sand + Gravel	W	113	120	7
Sand + Medium Gravel	W	120	140	20
Hard Sand		140	145	5
Sand - Gravel	W	145	161.5	16.5

Date started Dec 12, 1997
Date completed Dec 26, 1997

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
?	?	0	2 hr

8. WELL CONSTRUCTION
Depth Drilled 161.5 Feet Depth Cased 161.5 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 ¼	Inches	0	Feet	105	Feet
10	Inches	105	Feet	161.5	Feet
—	Inches	—	Feet	—	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		0.188	0	161.5
8 5/8		0.188	-2	0

Perforations:
Type perforation Mill Field
Size perforation ½ x 4 10 Row ¼ x 6 4 Row
From 101.5 feet to 141.5 feet
From 141.5 feet to 161.5 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 161.5 feet to 50 feet

9. WATER LEVEL
Static water level 105 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Warm °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name C-D Co Contractor
Address PO Box 26
Amargosa Valley, NV 89020
Contractor
Nevada contractor's license number issued by the State Contractor's Board 0014214
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1127
Signed
By driller performing actual drilling on site or contractor
Date 12-28-97

(Rev. 3-91) W-35-97-2 File

USE ADDITIONAL SHEETS IF NECESSARY

KC

(O)-627