WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69892
Permit No.
Basin 125

NOTICE OF INTENT NO. 31447

1. OWNER Douglas Co. Sewer Improvement Dist #1
MAILING ADDRESS JWA Eng. P.O. Box 1819
Zepher Cove NV.
ADDRESS AT WELL LOCATION
Douglas Co. Sewer Improvment Dist.#1

2. LOCATION SE ¼ SW ¼ Sec. 7 T. 13 (N)S R. 21 E. Douglas County
PERMIT NO. M/O-455-B (Issued by Water Resources) 23-010-67 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	8	
Light brown clay &				
Gravel		8	15	
Boulders & Gravel		15	48	
Brown Clay & Gravel		48	65	
Conglomerate		65	90	
Clay & Boulders		90	100	
Fine Brown Sand		100	232	
Course Brown Clay		232	238	
Fine Brown Sand & Clay		238	242	
Med. Brown Sand		242	255	

Date started 3-19-97, 19
Date completed 7-9-97, 19

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX.	6.5	220	3.5

8. WELL CONSTRUCTION
Depth Drilled 255 Feet Depth Cased 255 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12¼	Inches	0	Feet	100	Feet
6 1/8	Inches	100	Feet	255	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	14	.188	-1	235
5 9/16	14.6	.258	232	255

Perforations:
Type perforation Well Screen (Roscoe Moss)
Size perforation 40 Slot
From 235 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From none feet to none feet

9. WATER LEVEL
Static water level 170 feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Miller & Sons Drilling (Contractor)
Address P.O. Box 8056 (Contractor)
Reno, NV 89507
Nevada contractor's license number issued by the State Contractor's Board 37915
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed Bruce Miller (By driller performing actual drilling on site or contractor)
Date 8-1-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627