WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69893
Permit No.
Basin 105

NOTICE OF INTENT NO. 31446

1. OWNER Douglas Co. Sewer Dist. #1
MAILING ADDRESS JWA Eng. P.O. Box 1819 Zepher Cove, NV

ADDRESS AT WELL LOCATION Douglas County Sewer Improvement District #1

2. LOCATION SW ¼ SE ¼ Sec. 7 T. 13 (N/S) R. 21 E. Douglas County
PERMIT NO. M/O 455-B (Issued by Water Resources) 23-010-68 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Light Brown Clay		0	1	
Brown Clay & Boulders		1	40	
Soft Brown sandy clay		40	72	
soft brown shale		72	88	
Dark Brown sandy clay		88	105	
Brown sand & gravel, Med-fine some clay		105	112	
Brn. sandy clay w/grav		112	125	
fine sand w/ clay		125	135	
soft brown shale		135	157	
hard sandy brown clay		157	201	
sand & gravel very fine to course		201	256	

Date started 3-20-97, 19
Date completed 5-16-97, 19

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60	225	5 hrs

8. WELL CONSTRUCTION
Depth Drilled 256 Feet Depth Cased 256 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼" Inches		0 Feet	43 Feet
10 3/4 Inches		43 Feet	112 Feet
6 1/8 Inches		112 Feet	256 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	14	.188	-2	231
5 ½		SS screen	227	251

Perforations:
Type perforation Well Screen (Roscoe Moss)
Size perforation 45 Slot
From 227 feet to 251 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From none feet to none feet

9. WATER LEVEL
Static water level 194 feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature cold °F Quality ?

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Miller & Sons Drilling co. (Contractor)
Address P.O. Box 8056 (Contractor)
reno, NV 89507
Nevada contractor's license number issued by the State Contractor's Board 37915
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed (By driller performing actual drilling on site or contractor)
Date 8-1-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627