WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69923
Permit No.
Basin 212

NOTICE OF INTENT NO. 14397

1. OWNER NDEP
MAILING ADDRESS 555 E. WASHINGTON AVE #4300 LAS VEGAS NV 89101
ADDRESS AT WELL LOCATION IN THE LEFT TURN LANE OF MARYLAND PKWY SOUTH OF FLAMINGO RD.

2. LOCATION NW ¼ NW ¼ Sec. 23 T. 21 N OR 61 E CLARK County
PERMIT NO. MO-2532 Issued by Water Resources
162-22-502-003 Parcel No.
Subdivision Name

3. WORK PERFORMED: ☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-7: ☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT/FILL		0	2.5	2.5
SILTY SAND		2.5	7	4.5
CALICHE		7	7.5	0.5
SILTY SAND		7.5	10	2.5
SILTY CLAY		10	19	9
CALICHE		19	20	1
SILTY CLAY		20	25	5

RECEIVED
FEB 14 1995
Div. of Water Resources
Branch Office : Las Vegas, NV

Date started JANUARY 19 1995
Date completed JANUARY 19 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	25 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	25

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 10 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-4'/4-6" BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 6 feet to 25 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGH
Contractor
Address 416 TO SO. POLARIS AVE
Contractor
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
Signed
By driller performing actual drilling on site or contractor
Date 2-13-95

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627