WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69928
Permit No.
Basin 212
NOTICE OF INTENT NO. 8849

1. OWNER Clark County School District
MAILING ADDRESS P.O. Box 98551
Las Vegas, Nevada 89193-8551

ADDRESS AT WELL LOCATION 4260 Eucalyptus
Las Vegas, Nevada 89121

2. LOCATION NE ¼ NW ¼ Sec. 24 T. 21 N/S R. 61 E. Clark County
PERMIT NO. MD-2099 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	0.3	0.3
Base Gravel		0.3	1.0	0.7
Sandy Clay/Silty Clay	water	1.0	9.0	8.0
Clayey Sand	"	9.0	10.0	1.0
Sandy Clay	"	10.0	26.0	16.0

RECEIVED
DEC 04 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 10/31, 19 91
Date completed 10/31, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 26 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches	0 Feet	25 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.04	0.25	0	25

Perforations:
Type perforation slotted
Size perforation 0.020
From 5 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 2
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 4 feet to 26 feet

9. WATER LEVEL
Static water level 7.40 feet below land surface
Artesian flow 0 G.P.M. P.S.I.
Water temperature 77 °F Quality cloudy

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Kleinfelder Contractor
Address 6850 Paradise Rd. Contractor
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1591
Signed [signature] By driller performing actual drilling on site or contractor
Date 11/27/91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627