WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69945
Permit No.
Basin 212

NOTICE OF INTENT NO. 14411

1. OWNER AVIS/GRAND RENT
MAILING ADDRESS 5721 W. 96th ST LOS ANGELES, CA 90045
ADDRESS AT WELL LOCATION 5164 RENT-A-CAR ROAD, LAS VEGAS, NV

2. LOCATION SE ¼ NW ¼ Sec. 27 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. MO-2522B (Issued by Water Resources) 162-27-201-005 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE A-7
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT/FILL		0	4	4
SANDY GRAVEL		4	8	4
GRAVELLY SAND		8	11.5	3.5
SILTY SAND		11.5	12	0.5
CALICHE		12	15	3
SANDY SILT		15	35	20

RECEIVED
APR 10 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started FEB 23, 19 95
Date completed FEB 23, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	35 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	35

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 15 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-3'/3-5' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 5 feet to 35 feet

9. WATER LEVEL
Static water level 17.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DONALD WILSON
Contractor
Address 4670 SO. POLARIS AVE
Contractor
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed
By driller performing actual drilling on site or contractor
Date 3-21-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627