WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69958
Permit No.
Basin 212

NOTICE OF INTENT NO. 11246

1. OWNER Hughes Aviation Services
MAILING ADDRESS 3800 Howard Hughes Pkwy Las Vegas NV 89109

ADDRESS AT WELL LOCATION Northeast corner Dewey Dr & Haven St Las Vegas - Hughes Executive Terminal

2. LOCATION SE ¼ SW ¼ Sec. 28 T. 21 N/S. R. 61 E. Clark County
PERMIT NO. [redacted] MO-2199 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY	N	1.5	6.5	5
CALICHE	N	6.5	8	1.5
GRAVELLY SAND	N	8	12	4
SANDY CLAY - w/ gravel	N	12	19	7
CALICHE	N	19	22.5	3.5
SILTY CLAY - w/ cal layers	N	22.5	38.5	16
CALICHE	N	38.5	39	0.5
SILTY CLAY - red brn	N	39	51	12
SILTY CLAY - red brn w/ sand	Y	51	60.5	9.5

RECEIVED
OCT 05 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 9/11, 1992
Date completed 9/11, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
n/a			

8. WELL CONSTRUCTION
Depth Drilled 60.5 Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
5 1/8 Inches	0 Feet	60.5 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		sch 40 PVC	0	60

Perforations:
Type perforation slotted screen
Size perforation 0.020 - inch
From 60 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 44'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 45 feet

9. WATER LEVEL
Static water level 51.1 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature — °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Tim Aten c/o Western Technologies Inc (Contractor)
Address 3611 W. Tompkins Ave (Contractor)
Las Vegas NV 89103
Nevada contractor's license number issued by the State Contractor's Board [redacted]
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1761
Signed (driller performing actual drilling on site or contractor)
Date

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627