WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69962 in book
Permit No.
Basin 212

NOTICE OF INTENT NO. 10110

1. OWNER Mr. Randy Gilbert
MAILING ADDRESS 6321 Hummingbird Lane Las Vegas, Nevada 89103

ADDRESS AT WELL LOCATION Southeast Corner of Procyon Avenue and Hacienda Avenue, Las Vegas NV

2. LOCATION NW ¼ SW ¼ Sec. 29 T 21 S R 61 E Clark County
PERMIT NO. MO 2557 Issued by Water Resources
162-29-301-025 Parcel No.
— Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. SKIP-1 LITHOLOGIC LOG ~~Model~~

Material	Water Strata	From	To	Thickness
Sandy Gravel		0	6	6
Caliche		6	13	7
Silt + Sand		13	19	6
Clay		19	22	3
Gravelly Sand		22	35	13
Caliche		35	37	2
Sandy Gravel		37	40	3
Clayey Gravel		40	42	2
Clayey Sand		42	44	2
Caliche		44	49	5
Sand + Gravel		49	51	2
Clay-sandy		51	61	10
Clay & trace Sand		61	75	14

RECEIVED MAR 22 1995 Div. of Water Resources Branch Office Las Vegas, NV

Date started March 16, 1995
Date completed March 16, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 75 Feet Depth Cased 68 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	75 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2			0	68

Perforations:
Type perforation slotted screen
Size perforation
From 48 feet to 68 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-41'
Placement Method: ☐ Pumped ☒ Poured
Sand ~~Gravel~~ Packed: ☒ Yes ☐ No
From 44 feet to 68 feet

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water-level 51' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Contractor
Address Contractor

Nevada contractor's license number issued by the State Contractor's Board —
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1761
Signed By driller performing actual drilling on site or contractor
Date 3/21/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627