WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69972
Permit No.
Basin 212

NOTICE OF INTENT NO. 12122

1. OWNER CALNEV Pipeline Company
MAILING ADDRESS
ADDRESS AT WELL LOCATION Corner of Valley View and Hacienda

2. LOCATION SE ¼ NE ¼ Sec. 30 T. 21 N/S R. 61 E/W County
PERMIT NO. ~~N/A~~ MO-2280 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Unsuccessfully attempted to pull casing from well.				
Grouted well with cement/bentonite slurry to a depth of 35 feet below ground surface and allowed to set for 24 hours.				
Grouted well with cement/bentonite slurry to a depth of 5 feet below ground surface and allowed to set for 24 hours.				
Over drilled well to a depth of 20 feet below ground surface.				
Protective seal placed in well between a depth of 15 and 20 feet below ground surface.				
Original N.O.I. = 10181				

RECEIVED OCT 27 1993 Div. of Water Res. Branch Office - Las Vegas

Date started 10/13, 1993
Date completed 10/18, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name (Contractor) CONVERSE CONSULTANTS SOUTHWEST
Address (Contractor) 4670 S. POLARIS AVE. LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 0034757
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
Signed (By driller performing actual drilling on site or contractor)
Date 10/22/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627