WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 69985
Permit No.
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15987

1. OWNER Mark Group
MAILING ADDRESS 2300 Paseo Del Prado Las Vegas Nev 89102
ADDRESS AT WELL LOCATION Hughes Executive Air Terminal

2. LOCATION N.E. ¼ N.W. ¼ Sec. 33 T. 21 S/S R. 61 E. Clark County
PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. hole # MW-7 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand gravel		0	3'	
Caliche		3'	12'	
Sand silt		12'	19'	
Caliche		19'	21'	
Sand		21'	27'	
Sand gravel		27'	33'	
Silt clay gravel		33'	37'	
Sand gravel	X	37'	55'	
Silt clay	X	55'	65'	

RECEIVED
MAY 08 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 12-10, 19 90
Date completed 12-10, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 8" inches Total depth 65' feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness .....

Diameter	From	To
4" inches	0 feet	65' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type bent. pellets 48'-45'
Depth of seal neat cement 45'-0 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 48' feet to 65' feet

Perforations:
Type perforation Manufacturer
Size perforation .020 inch
From 50' feet to 65' feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 52' feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cold °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Dave's Drilling (Contractor)
Address 5617 W. Wells Pk Rd W. Jordan UT 84088 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board [redacted] 0027284
Nevada contractor's driller's number issued by the Division of Water Resources 1705
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1705
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4-28-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627