WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 69986
Permit No.
Basin 212

WELL DRILLER'S REPORT

Please complete this form in its entirety in Book

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15988

1. OWNER Mark Group
MAILING ADDRESS 2300 Paseo Del Prado Las Vegas Nev 89102
ADDRESS AT WELL LOCATION Hughes Executive Air Terminal

2. LOCATION NE ¼ NW ¼ Sec. 33 T. 21 N/S R. 61 E. Clark County
PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. hole# MW-6 LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand gravel		0	2'	
caliche		2'	8'	
silt		8'	10'	
caliche		10'	22'	
silt sand clay		22'	29'	
caliche		29'	40'	
silt sand gravel	X	40'	55'	
silt sand clay	X	55'	83'	

RECEIVED
MAY 08 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 12-5, 1990
Date completed 12-6, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 8" inches Total depth 83' feet
____ inches
____ inches
Casing record ____
Weight per foot ____ Thickness ____

Diameter	From	To
4" inches	0 feet	80' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type bent. pellets, neat cement
Depth of seal 47' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 83' feet to 47' feet

Perforations:
Type perforation Manufacturer
Size perforation .020 inch
From 50' feet to 80' feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 53' feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature Cold °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Dave's Drilling (Contractor)
Address 5617 W. Wells Pk. Rd. W Jordan UT 84088 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board [redacted] 0027284
Nevada contractor's driller's number issued by the Division of Water Resources 1705
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1705
Signed [signature]
By driller performing actual drilling on site or contractor
Date 4-28-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627