

OFFICE USE ONLY  
 Log No. 70071  
 Permit No. 179  
 Basin 179  
 NOTICE OF INTENT NO. 33059  
10 miles north of Ely

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534:170 and NAC 534.340

1. OWNER Brandon Vaught ADDRESS AT WELL LOCATION 10 miles north of Ely  
 MAILING ADDRESS Box 445  
Ely, NV 89301  
 2. LOCATION NE 1/4 NE 1/4 Sec 7 T 17 N/S R 63 E White Pine County  
 PERMIT NO. 1031019  
 Issued by Water Resources APN ~~XXXX~~ Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top-Soil-		0	5	5
Gravel		5	15	10
Gravel & Clay		15	20	5
Gravel		20	45	25
Clay & Gravel		45	50	5
Water Bearing Sand & Gravel	x	50	140	90

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	140

Perforations:  
 Type perforation Factory  
 Size perforation 1 7/8" x 2 1/2" 6 rows  
 From 60 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 30 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

Date started October 2, 19 97  
 Date completed October 4, 19 97

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>350</u>	<u>90</u>	<u>1</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Christiansen Drilling, Inc.  
 Address 557 Ely Avenue  
Ely, NV 89301  
 Nevada contractor's license number issued by the State Contractor's Board 14790  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641  
 Signed Judd D. Christiansen  
 By driller performing actual drilling on site or contractor  
 Date October 8, 1997