WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70073
Permit No.
Basin 79

NOTICE OF INTENT NO. 33057

1. OWNER Harold Standley
MAILING ADDRESS HC 1 Box 2
Bayview, Idaho 83803

ADDRESS AT WELL LOCATION 6 miles north of Ely

2. LOCATION SW ¼ NE ¼ Sec. 9 T. 17 N/~~S~~ R. 63 E. White Pine County
PERMIT NO. (Issued by Water Resources) 10-800-02
APN ~~xxxxxx~~ (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Shaley Limestone		0	60	60
Dark Gray Limestone		60	120	60
White Limestone		120	140	20
Light Gray Limestone		140	150	10
White Limestone		150	185	35
Light Gray Limestone		185	205	20
Dark Brown Limestone	x	205	210	5
Light Gray Limestone		210	240	30
Volcanics		240	245	5
Light Gray Limestone		245	255	10
Dark Gray Limestone		255	280	25
Volcanics		280	285	5
Dark Gray Limestone		285	295	10
Light Gray Limestone		295	300	5

Date started September 13, 19 97
Date completed September 19, 19 97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	100	1½

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	300 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	300

Perforations:
Type perforation Factory
Size perforation 1/8" x 2½" 6 rows
From 180 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 68 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue
Ely, NV 89301 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641

Signed Jerald D. Christiansen (By driller performing actual drilling on site or contractor)
Date October 8, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627