WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70122
Permit No.
Basin

NOTICE OF INTENT NO. 15772

1. OWNER: Clark County Schools
MAILING ADDRESS: 2832 E. Flamingo
Las Vegas, Nv 89121

ADDRESS AT WELL LOCATION: Hacienda & Denning
Las Vegas, Nv

2. LOCATION XXX ¼ XXXX ¼ Sec. 28 T. 21 N/S R. 62 E. Clark County
PERMIT NO. DW-1071 (Issued by Water Resources) | 161-28-301-001/002/003 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
XX New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon XX Other Dewater

4. PROPOSED USE dewater
☐ Domestic XX Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Dewater

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| 4 Dewatering Wells | | | | |
| Dirt and Sand | 5' | 0' | 5' | 5' |
| Sandy Silty Clay | | 6' | 15' | 9' |
| Clay Some pea Gravel | | 16' | 30' | 14' |

Date started 9-10-97, 19
Date completed 9-10-97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 30' Feet Depth Cased 30' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24" Inches | 0 Feet | 24" Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 24" | | 3/4" | 0 | 30 |
| | | | | |
| | | | | |

Perforations:
Type perforation Machine perforated
Size perforation 14
From 0 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes XX No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 5' feet below land surface
Artesian flow 50 G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allen Drilling Inc. (Contractor)
Address 4847 S. Valley View (Contractor)
Las Vegas, Nv 89103
Nevada contractor's license number issued by the State Contractor's Board 0018916
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301
Signed [signature] (By driller performing actual drilling on site or contractor)
Date October 6, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627