

Water Sample Boiling

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 70136

Permit No. 212

Basin. 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12000

1. OWNER HVA ADDRESS AT WELL LOCATION MCCARRON AIRPORT

MAILING ADDRESS 4170 S. Decatur A-1
Las Vegas, NV 89103

2. LOCATION E 1/2 1/4 NW 1/4 Sec 33 T 21 N 61 E Clark County

PERMIT NO. NO-2320 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED

New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE

Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Clays w/sands</u> <u>caliche layers</u>		<u>0</u>	<u>57</u>	
<u>Clay w/some</u> <u>sands</u>		<u>57</u>	<u>63</u>	

8. WELL CONSTRUCTION

Depth Drilled 63 Feet Depth Cased NA Feet

HOLE DIAMETER (BIT SIZE)

From 0 To 63

8 Inches 0 Feet 63 Feet

..... Inches Feet Feet

..... Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>NA</u>				

Perforations:

Type perforation NA

Size perforation

From feet to feet

Surface Seal: Yes No Seal Type:

Depth of Seal 63 Neat Cement

Placement Method: Pumped Cement Grout

Poured Concrete Grout

Gravel Packed: Yes No

From NA feet to feet

9. WATER LEVEL

Static water level 58 feet below land surface

Artesian flow G.P.M. P.S.I.

Water temperature °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Webber Environmental Contractor

Address 4301 S Valley View #21 Contractor

Las Vegas NV. 89103

Nevada contractor's license number issued by the State Contractor's Board C-2310035639

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1487

Signed [Signature] By driller performing actual drilling on site or contractor

Date 10-25-93

Date started 8-26-93, 19.....

Date completed 8-26-93, 19.....

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED

NOV 02 1993

Div. of Water Resources
Branch Office - Las Vegas, NV

Hole was cemented
from bottom to top.