WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.3[illegible]

OFFICE USE ONLY
Log No. 70462
Permit No. 13393
Basin 212

NOTICE OF INTENT NO. 16242

1. OWNER ITT SHERATON DESERT INN
MAILING ADDRESS
ADDRESS AT WELL LOCATION 3139 LAS VEGAS BLVD. SO.
LAS VEGAS, NV 89109

2. LOCATION NE ¼ NW ¼ Sec. 16 T 21 N/S R 61 E CLARK County
PERMIT NO. 13393 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [X] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	10	10
CALICHE		10	30	20
CLAY & GRAVEL		30	40	10
GRAVEL & SAND		40	45	5
CLAY		45	290	245
CEMENTED GRAVEL	X	290	320	30
CLAY		320	400	80
SAND & GRAVEL	X	400	440	40
CLAY & SILT		440	500	60

OLD WELL PLUGGED TO STATE SPECIFICATIONS BY PUMPING 11 YARDS NEET CEMENT FROM BOTTOM UP TO SURFACE

Date started 8/9, 1997
Date completed 8/21, 1997

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
14 Inches	0 Feet	500 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.9	.188	+2	500

Perforations:
Type perforation SCREEN
Size perforation .050 SLOT
From 240 feet to 440 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 60 feet to 500 feet

9. WATER LEVEL
Static water level 117 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WATER WELL SERVICES (Contractor)
Address 6475 GARY AVE. (Contractor)
LAS VEGAS, NV 89139
Nevada contractor's license number issued by the State Contractor's Board 022311
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1963
Signed (By driller performing actual drilling on site or contractor)
Date 9/2/97

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627