WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70179
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK
32
WELL# BV-35

NOTICE OF INTENT NO.

1. OWNER MARNELL CORRAO
MAILING ADDRESS 4495 S. POLARIS AVE
LAS VEGAS, NV

ADDRESS AT WELL LOCATION BELLAGIO
FLAMINGO AND LVAS VEGAS BLVD.
LAS VEGAS

2. LOCATION SE ¼ SE ¼ Sec. 22 T 21 N/S R 61 E CLARK County
PERMIT NO. DW 1038 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE Dewater
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SAND | | 0 | 7 | 7 |
| SAND AND CLAY | | 7 | 19 | 11 |
| CALICHI | | 19 | 21 | 2 |
| WHITE CLAY | | 21 | 28 | 7 |
| AND GRAVEL | | 28 | 40 | 12 |

Date started 10/24/95, 19
Date completed 10/24/95, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| | | | |

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 24 Inches | 0 Feet | 40 Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 14 | 38.71 | 1/4" | 0 | 40 |
| | | | | |
| | | | | |

Perforations: FACTORY
Type perforation 1/4" 2 1/2"
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From 0 feet to 40 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. Contractor
Address 4847 S. VALLEY VIEW Contractor
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661
Signed By driller performing actual drilling on site or contractor
Date 1-16-96

RECEIVED JAN 22 1996 LAS VEGAS OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627