INJ 9-2

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70224
Permit No.
Basin 66

NOTICE OF INTENT NO. 38452

1. OWNER NEWMONT EXPLORATION LTD.
MAILING ADDRESS P.O. BOX 69
GOLCONDA, NV 89414

ADDRESS AT WELL LOCATION
TWIN CREEKS MINE SITE

2. LOCATION SE ¼ NE ¼ Sec. 9 T 38 (N)S R 43 E HUMBOLDT County

PERMIT NO. M/O 1151 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic Injection [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other FLOODED

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL GRAVELS		0	20	20
GRAVELS CLAYS		20	220	200
BROWN CLAY		220	250	30
GRAVEL AND CLAY		250	400	150

RECEIVED 97 NOV 17 AM 11:24 STATE ENGINEER'S OFFICE

Date started OCTOBER 28, 19 97
Date completed NOVEMBER 11, 19 97

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
345	21	1 HOUR

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 390 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
25 Inches	0 Feet	20 Feet
19 Inches	20 Feet	400 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20	78.6	.375	+1	20
12 3/4	33.3	.250	+2	390

Perforations:
Type perforation WIRE WRAP STAINLESS STEEL
Size perforation .035
From 130 feet to 370 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 125
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 125 feet to 400 feet

9. WATER LEVEL
Static water level 103 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature WARM °F Quality FAIR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address P.O. BOX 5279 (Contractor)
ELKO, NV 89802
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1948
Signed Daryl Blossman (By driller performing actual drilling on site or contractor)
Date 11-12-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627