WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70272
Permit No.
Basin 162

NOTICE OF INTENT NO. 17060

1. OWNER William Beemon
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1671 W. LOST CREEK DR.

2. LOCATION SE ¼ NW ¼ Sec. 29 T. 20-S N/S R. 53 E. NYE County
PERMIT NO. (Issued by Water Resources) 39-022-12 (Parcel No.) Calvada Valley UT: 8-B BLK 8 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Brown clay		4	8	4
Gray clay		8	15	7
Blue clay		15	24	9
Limestone		24	30	6
Gray clay/caliche		30	51	21
Gray clay	X	51	72	21
Gray clay/caliche		72	94	22
Brown clay	X	94	128	34
Brown clay/caliche		128	140	12

DC Received FEB 5 1998 LAS VEGAS OFFICE

Date started JAN. 20, 19 98
Date completed JAN. 20, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Torch Cut
Size perforation ¼" width 8" long
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JIM PIKE WELL DRILLING, LLC. (Contractor)
Address P. O. BOX 56 (Contractor)
PAHRUMP, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 17563A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812
Signed [signature] By driller performing actual drilling on site or contractor
Date JANUARY 26, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627