

70322

OFFICE USE ONLY
 No. 111224
 No.
 Basin

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 116897

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Eizman's Services Exxon
 MAILING ADDRESS 350 Front Street
Caliente, Nevada 89009
 2. LOCATION NE 1/4 of NW 1/4 of SW 1/4 Sec. 8 T. 41 N. R. 67 E. Lincoln
 PERMIT NO. MO-2064 3-089-02 Caliente
Issued by Water Resources Parcel No. Subdivision Name

ADDRESS AT WELL LOCATION lot 8, 9, 10, 11 Block 13
City of Caliente, Nevada

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other Sampling

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Hydro-punch

6. LITHOLOGIC LOG


Material	Water Strata	From	To	Thickness
WELL # 11				
<p>On January 9th and 10th 1996, 13 sampling points were drilled to a depth of approximately 5 feet. The soil encountered were a blackish silty sand and a blackish sandy clay. A one inch hydro-punch was then driven to approximately 8 feet to obtain water sample. The sampling points were then abandoned by backfilling the sampling points with bentonite to approximately one foot below grade and then completed with concrete on water fill as required per water MO 2064.</p>				

8. WELL CONSTRUCTION
 Depth Drilled 8 Feet Depth Cased 0 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
6 Inches 0 Feet 5 Feet
1 Inches 5 Feet 8 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>N/A</u>				

Perforations:
 Type perforation
 Size perforation
 From feet to feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 7.5 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From feet to feet



9. WATER LEVEL
 Static water level: 7.2 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature 60.1 °F Quality

Date started January 9, 1996
 Date completed January 10, 1996

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Les Jones Contractor
 Address 7560 W. Sahara Ste 101 Contractor
Las Vegas, Nevada 89117
 Nevada contractor's license number N/A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1986
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 1-24-96