

OFFICE USE ONLY
 Log No. 70374
 Permit No. _____
 Basin 70

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33293

1. OWNER EDA SELECTIVE PROP ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 398 HWY 50 NEW ROUND HILL, NV DOUGLAS County
 2. LOCATION 1/4 SE 1/4 Sec 15 T 13 S R 18 E
 PERMIT NO. OLD NO. 418 APN 05-550-003 Subdivision Name _____
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG NEW MDS

| Material | Water Strata | From | To | Thick-ness |
|--------------------------------|--------------|------------|------------|------------|
| <u>SANDS & GRAVEL</u> | | <u>0'</u> | <u>9'</u> | |
| <u>SANDS & CORBLES</u> | | <u>9'</u> | <u>13'</u> | |
| <u>SANDS & SILTS</u> | | <u>13'</u> | <u>20'</u> | |
| <u>DENSE SANDS & SILTS</u> | <u>27.5'</u> | <u>20'</u> | <u>30'</u> | |

8. WELL CONSTRUCTION
 Depth Drilled 30' Feet Depth Cased 30' Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 30 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>2"</u> | <u>PK</u> | <u>SCH 40</u> | <u>0</u> | <u>30</u> |

Perforations:
 Type perforation FACTORY
 Size perforation .020
 From 15' feet to 30' feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 14' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 14' feet to 30' feet

9. WATER LEVEL
 Static water level 27.5 feet below land surface
 Artesian flow NO G.P.M. NA P.S.I.
 Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ANDRESEN DRILLING Contractor
 Address 1655 BELFORD RD. Contractor
2610, NV 89509
 Nevada contractor's license number issued by the State Contractor's Board 34525
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 8/20/97

Date started 06/12, 1997
 Date completed 06/12, 1997

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |
| | | <u>N/A</u> | |

RECEIVED
 98 JUN 30 11:12
 STATE ENGINEERING OFFICE