

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12975

1. OWNER CHRIS TREASE ADDRESS AT WELL LOCATION 1/4 MILE EAST OF HWY 376 AT SMOKY JOE'S
MAILING ADDRESS HC 60 Box 77301 ROUND MTN NEVADA 89045 HC 60 Box 77510 ROUND MTN NEV 89045

2. LOCATION NE 1/4 NE 1/4 Sec 2 T 14 N/S R. 43 E. NYE County _____
PERMIT NO. 10-451-11 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BRN CLY		0	6	6
SMALL GRAVEL		6	9	3
BLACK CLY		9	13	4
FINE SAND		13	17	4
DARK BRN CLY		17	28	11
SMALL GRAVEL		28	34	6
TAN CLY		34	37	3
COARSE SAND		37	39	2
BRN CLY		39	46	7
COARSE SAND		46	51	5
TAN CLY		51	64	13
SAND		64	67	3
TAN CLY		67	80	13
SMALL GRAVEL		80	83	3
BRN CLY		83	90	7
FINE SAND		90	92	2
BRN CLY		92	104	12
SMALL GRAVEL		104	106	2
WHITE CLY		106	110	4
SMALL GRAVEL	X	110	113	3
BRN CLY & SAND STRINGS		113	128	15
COARSE SAND	X	128	132	4
BRN CLY		132	136	4
COARSE SAND & CLY STRINGS	X	136	150	14

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)
From To
10 5/8 Inches 0 Feet 50 Feet
8 3/4 Inches 50 Feet 150 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>1.88</u>	<u>72</u>	<u>150</u>

Perforations:
Type perforation MILLER
Size perforation 3 1/8
From 130 feet to 150 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level Flowing feet below land surface
Artesian flow 40 G.P.M. _____ P.S.I.
Water temperature 60.0 °F Quality Good

Date started 1-7-98, 19. 98
Date completed 1-8-98, 19. 98

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>150</u>	<u>8'</u>	<u>4 HRS</u>	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WOYTEK DRILLING CO INC. Contractor
Address 2220 STONE DRIVE Contractor
RENO NEV 89511
Nevada contractor's license number issued by the State Contractor's Board 024521A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
Signed Thomas M. Hanks
By driller performing actual drilling on site or contractor
Date 1-9-98