WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70382
Permit No.
Basin 7

NOTICE OF INTENT NO. 33470

1. OWNER Garret VanDizet
MAILING ADDRESS PO Box 867
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION
6 #lot Block A Joaquin Drive Winnemucca

2. LOCATION NW ¼ NE ¼ Sec. 1 T. 34 N/S R. 37 E. Pershing County
PERMIT NO. Domestic (Issued by Water Resources) | LOT 6 Block A (Parcel No.) | Sonoma View Estates (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Topsoil | | 0 | 10 | 10 |
| Clay | | 10 | 70 | 60 |
| Gravel Sand | Yes | 70 | 100 | 30 |

8. WELL CONSTRUCTION
Depth Drilled [illegible] Feet Depth Cased 100' Feet

HOLE DIAMETER (BIT SIZE)

| | From | |
|---|---|---|
| 10 5/8 Inches | 0 Feet | 100 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12 | 188 | +1 | 100 |
| | | | | |
| | | | | |

Perforations:
Type perforation Factory cut
Size perforation 5/32 X 4
From 80 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 34' feet below land surface
Artesian flow n/A G.P.M. P.S.I.
Water temperature Cod °F Quality Good

Date started Jan 4, 1997
Date completed Jan 5, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | 3hr |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling (Contractor)
Address 10760 Grass Valley Rd (Contractor)
Winn, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Jan 10 98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627