WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70387
Permit No.
Basin 105

NOTICE OF INTENT NO. 28000

1. OWNER Tony Avanzino
MAILING ADDRESS 1284 Lariata Ct. Minden NV. 89410
ADDRESS AT WELL LOCATION 1944 Horsebush Ct. Gardnerville NV. 89410

2. LOCATION NE ¼ SW ¼ Sec. 36 T. 13 N/S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) 23-472-14 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay and Cobbles		0	28	28
Brown Clay		28	100	72
Brown Sandy Clay		100	170	70
Hard Black Volcanic		170	210	40
Black Soft Sands (Fine) Volcanic		210	260	50
Gray Clay (Gummy)		260	498	238
Soft Fractured Area Green Sands Stained Rock. Some Rusty	XX	498	545	47

Date started 1-3, 19 98
Date completed 1-9, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
19	150	5 HRS

8. WELL CONSTRUCTION
Depth Drilled 545 Feet Depth Cased 545 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11¼ Inches	0 Feet	545 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	545

Perforations:
Type perforation Mill Slot
Size perforation 3x 3/32
From 505 feet to 545 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 545 feet

9. WATER LEVEL
Static water level 200 feet below land surface
Artesian flow G.P.M. 19 P.S.I.
Water temperature Warm °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling (Contractor)
Address 20 Kit Kat DR. (Contractor)
Carson City NV. 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hoek (By driller performing actual drilling on site or contractor)
Date 1/9/98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627