WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70394
Permit No.
Basin 102

NOTICE OF INTENT NO. 31996

1. OWNER Tim Elliott
MAILING ADDRESS 1060 Onyx Silver Springs
ADDRESS AT WELL LOCATION Same

2. LOCATION NW ¼ NW ¼ Sec. 15 T 18 N S R 24 E Lyon County
PERMIT NO. Issued by Water Resources
Parcel No. 15-121-04
Subdivision Name none

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	1	1
Clay		1	4	3
Rock		4	20	16
Brown Clay		20	60	40
White Clay		60	70	10
Brown Clay		70	80	10
Gravel		80	100	20
Limestone		100	125	25
Clay		125	160	35
Clay & Gravel		160	180	20
Clay		180	185	5
Clay & Gravel		185	190	5
Limestone		190	200	10
Clay & Gravel		200	210	10
Limestone		210	250	40
Clay		250	265	15
Coarse Sand		265	270	5
Lime Stone		270	272	2
Clay		272	274	2
Sand & Gravel		274	279	5
Black Basalt		279	310	31
Clay		310	320	10
Coarse Sand & Gravel	✓	320	347	27

Date started Aug 30, 1997
Date completed Jan 10, 1998

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5	40	1

8. WELL CONSTRUCTION
Depth Drilled 349 Feet Depth Cased 347 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	65 Feet
6 Inches		0 Feet	347 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	1377	.188	0	347
			16" above grnd	

Perforations:
Type perforation Machined
Size perforation 1/8 x 3
From 325 feet to 345 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 651
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 260 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature warm °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vern Cannon
Contractor
Address 4555 Hwy 50 W
Contractor
Silver Springs, NV 89429
Nevada contractor's license number issued by the State Contractor's Board 23317
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1455
Signed Vernon Cannon Jr.
By driller performing actual drilling on site or contractor
Date 1/20/98

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627