WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70401
Permit No.
Basin 101

NOTICE OF INTENT NO. 37065

1. OWNER EVERETT KISSICK
MAILING ADDRESS 5845 MacPherson Ln Fallon, NV.
ADDRESS AT WELL LOCATION 1165 Dean Ln Fallon, NV. LOT 4

2. LOCATION SW¼ SW ¼ Sec. 20 T. 19 N/S R. 28 E. CHURCHILL County
PERMIT NO. (Issued by Water Resources) Parcel No. 008-552-24 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	30'	30'

8. WELL CONSTRUCTION
Depth Drilled 30' Feet Depth Cased 30' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10" Inches	0' Feet	30' Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	18	3/16	0	30'

Perforations:
Type perforation Slots
Size perforation 1/16 x 3"
From 25 feet to 30' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 25'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 25' feet to 30' feet

9. WATER LEVEL
Static water level 12' feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Farris Drilling (Contractor) 1185 Tice
Address Fallon NV 89406 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 048145
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2082
Signed (By driller performing actual drilling on site or contractor)
Date 1-26-98

Date started 1-24, 1998
Date completed 1-24, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
53	81	4HRS

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627