

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 2511

1. OWNER China ARMUR ADDRESS AT WELL LOCATION 2577 W. 7th St. Las Vegas, NV 89102  
 MAILING ADDRESS 1400 S. Grand Ave. Las Vegas, NV 89102  
 2. LOCATION 1/4 Sec. 26 T. 34 N. S. R. 55 E. 7th E County Clark  
 PERMIT NO. 197-5-10000 Issued by Water Resources Parcel No. 100-1-10000 Subdivision Name 100-1-10000

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Loam</u>		<u>0</u>	<u>6"</u>	<u>6"</u>
<u>Light gray sand</u>		<u>6"</u>	<u>159'</u>	<u>153'</u>
<u>Light gray</u>		<u>159'</u>	<u>201'</u>	<u>42'</u>
<u>Light gray sand</u>		<u>201'</u>	<u>234'</u>	<u>33'</u>
<u>Light gray</u>		<u>234'</u>	<u>251'</u>	<u>17'</u>
<u>Light gray sand</u>	<u>X</u>	<u>251'</u>	<u>277'</u>	<u>26'</u>
<u>Light gray sand</u>		<u>277'</u>	<u>289'</u>	<u>12'</u>

8. WELL CONSTRUCTION  
 Depth Drilled 289' Feet Depth Cased 289' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
1 1/2 Inches 0 Feet 289' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1 1/2</u>	<u>12.12</u>	<u>1.00</u>	<u>0</u>	<u>289'</u>

Perforations:  
 Type perforation Mill  
 Size perforation 3/4"  
 From 289' feet to 289' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 289'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 289' feet to 289' feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 1-13 1988  
 Date completed 1-13 1988

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>10 min</u>	<u>15</u>		<u>30 min</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Robert Drilling Co Contractor  
 Address 2577 W. 7th St. Las Vegas, NV 89102 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 6021904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1984  
 Signed Robert Drilling Co  
 By driller performing actual drilling on site or contractor  
 Date 1-13-88