WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

11BCA

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70404
Permit No.
Basin 73

NOTICE OF INTENT NO. 37105

1. OWNER McConnell Coakwell
MAILING ADDRESS 216 Lemmon DRive, #268
Reno, Nevada 89506

ADDRESS AT WELL LOCATION 105 Alum Rock Ct.
Reno, Nevada 89506

2. LOCATION SW ¼ NW ¼ Sec. 11 T 22N N/S R 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 079-500-47 (Parcel No.) Antelope Valley (Red Rock Estates #2 Part 2) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Decomposed granite with brown clays		2	9	7
Weathered broken granite		9	31	22
Gray broken granite		31	90	59
Soft zone (NO WATER)		90	97	7
Green granite		97	190	93
Green hard granite		190	197	7
Gray granite		197	223	26
Fracture rock with clay streaks (NO WATER)		223	237	14
Gray granite		237	261	24
Fracture rock	X	261	276	15
Gray granite		276	280	4

Date started 12-11-97, 19
Date completed 12-12-97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18		

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	280 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	280

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 235 feet to 275 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 280 feet

9. WATER LEVEL
Static water level 242 feet below land surface
Artesian flow G.P.M. 18 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature] (By driller performing actual drilling on site or contractor)
Date December 15, 1997

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627