WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70414
Permit No.
Basin 162

NOTICE OF INTENT NO. 15559

1. OWNER James and Lisa Frazier
MAILING ADDRESS 3721 South Oakleaf Ave.
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
3721 South Oakleaf Ave.

2. LOCATION NE 1/4 SE 1/4 Sec. 31 T 20 N/S R 54E E Nye County
PERMIT NO. Issued by Water Resources
41-161-03 Parcel No.
Calvada Valley Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
lt. grey calache		0	25	25
lt. brown calache		25	46	21
brown calache		46	60	14
Grey clay		60	72	12
brown calache	x	72	110	38
Brown clay	x	110	132	22
calache	x	132	152	20
clay and calache	x	152	155	3

DCNR Received FEB 11 1998 Las Vegas

Date started 9/24/97, 19__
Date completed 9/24/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	n/a	.50

8. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 113 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 3/4	Inches	0	Feet	155	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	155

Perforations:
Type perforation Saw Cut
Size perforation .188
From 155 feet to 123 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 155 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road Suite 2 Contractor
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed Larry Strickland By driller performing actual drilling on-site or contractor
Date 9.24.97