WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70415
Permit No. 63451
Basin 162

NOTICE OF INTENT NO. 17346

OWNER Rupert Bragg-Smith
MAILING ADDRESS 3601 S. Hwy 160
Pahrump, NV 89048

ADDRESS AT WELL LOCATION 3601 S. Hwy 160

2. LOCATION NE 1/4 NE 1/4 Sec. 33 T 20S N/S R 54E E Nye County
PERMIT NO. 63451 (Issued by Water Resources) | Not Assigned (Parcel No.) | BLM Land (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE (COMMERCIAL)
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN LOAM & ROCK		0	15	15
BROWN LOAM & ROCK		15	30	15
BROWN LOAM & ROCK		30	60	30
CREAM CLAY & ROCK& GRAVEL		60	80	20
GREY CLAY & ROCK & GRAVEL		80	110	30
BROWN CLAY & GRAVEL	X	110	150	40
BROWN CLAY & GRAVEL	X	150	170	20
BROWN CLAY & SAND & GRAVEL		170	200	30
LIGHT BROWN SAND & GRAVEL	X	200	210	10
LIME STONE	X	210	250	40

DCNR Received FEB 1998

Date started 1/31/98, 19__
Date completed 1/31/98, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
.5	na	.50

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 7/8	Inches	0	Feet	250	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.250	0	250

Perforations:
Type perforation saw cut
Size perforation .188
From 210 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 250 feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. (Contractor)
Address 2301 Winery Road, Suite 2 (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed Larry Strickland (By driller performing actual drilling on-site or contractor)
Date 1.5.98