


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 70421  
 Permit No. \_\_\_\_\_  
 Basin 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17340

1. OWNER Larry Stoeckinger ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 4111 W. Elvira 4111 W. Elvira LOT#192  
Pahrump, NV 89048

2. LOCATION NE 1/4 SE 1/4 Sec. 26 T 20S N/S R 52E E Nye County  
 PERMIT NO. 28-614-13 Vegas Acres  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN CLAY		0	2	2
GREY CALACHE		2	16	14
GREY CALACHE		16	38	22
GREY CLAY		38	62	24
GREY CLAY	X	62	89	27
BROWN CLAY	X	89	116	27
BLACK LAVA ROCK	X	116	125	9

8. WELL CONSTRUCTION  
 Depth Drilled 125 Feet Depth Cased 125 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
12 7/8 Inches 0 Feet 125 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet


CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>125</u>

Perforations:  
 Type perforation saw cut  
 Size perforation .188  
 From 95 feet to 125 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 125 feet



Date started 1/23/98 \_\_\_\_\_, 19\_\_\_\_  
 Date completed 1/23/98 \_\_\_\_\_, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>.5</u>	<u>na</u>	<u>.50</u>

9. WATER LEVEL  
 Static water level 62 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Strickland Construction Co., Inc. Contractor  
 Address 2301 Winery Road, Suite 2 Contractor  
Pahrump, NV 89048  
 Nevada contractor's license number \_\_\_\_\_  
 Issued by the State Contractor's Board 40277  
 Nevada driller's license number issued by the \_\_\_\_\_  
 Division of Water Resources, the on-site driller 2086  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 1-26-98

