


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 70422
 Permit No. _____
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17339

1. OWNER Larry Stoeckinger ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4081 W. Elvira 4081 W. Elvira LOT#191
Pahrump, NV 89048

2. LOCATION NE 1/4 SE 1/4 Sec. 26 T 20S N/S R 52E E Nye County
 PERMIT NO. 28-614-13 Vegas Acres
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____


6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN CLAY		0	2	2
BROWN GALACHE		2	4	2
GREY CALACHE		4	18	14
GREY CLAY		18	30	12
GREY CLAY		30	49	19
GREY CLAY		49	60	11
LIGHT GREY CLAY	X	60	78	18
BROWN CLAY	X	78	110	32
GREY CLAY	X	110	118	8
BLACK LAVA ROCK	X	118	120	2

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 7/8 Inches 0 Feet 120 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>120</u>

Perforations:
 Type perforation SAW CUT
 Size perforation .188
 From 95 feet to 120 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 120 feet



Date started 1/21/98, 19____
 Date completed 1/21/98, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>.5</u>	<u>na</u>	<u>.50</u>

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
 Signed Chris Strickland
 By driller performing actual drilling on-site or contractor
 Date 1-26-98

