WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

70453

OFFICE USE ONLY
Log No. 70453
Permit No.
Basin 212

NOTICE OF INTENT NO. 16497

1. OWNER C.N.L.V. SANITATION DIVISION
MAILING ADDRESS 1003 E. BROOKS
NO. LAS VEGAS, NV 89030

ADDRESS AT WELL LOCATION A CHANNEL SEWER
INTERCEPTOR CHEYENNE TO OWNES
A CHANNEL SEWER PROJECT

2. LOCATION ____ ¼ ____ ¼ Sec. 30 T. 22 N/S R. 61 E. CLARK County
PERMIT NO. DW1074 (Issued by Water Resources) Parcel No. n/a Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Dewatering

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
6 Dewater Well drilled				
Sands silts		0	3'	
water		3'		
soupy sands & silts		3	10	
clays & silty sands		10'	20'	
gray clays stiff		20	25	
soupy bottom silt clay		25	29	
#3-8 wells				
S-side next to bridge				
on Pecos/Lake Mead				

Date started 11/12/97, 19
Date completed 11/13/97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 29' Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
24" Inches	0 Feet	30' Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	36.71	.250	-1	29

Perforations:
Type perforation Machine
Size perforation 1/4 x 2 1/2
From 20 feet to 30 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 29' feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (Contractor)
Address 4847 S. VALLEY VIEW (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301
Signed Fred B. Allen Jr. (By driller performing actual drilling on site or contractor)
Date 2/6/98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627