WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70477
Permit No.
Basin 162

NOTICE OF INTENT NO. 17333

1. OWNER Dorothy McHeigh
MAILING ADDRESS 9061 S. Desert Ln.
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
9061 S. Desert Ln.

2. LOCATION NE 1/4 NE 1/4 Sec. 36 T 21S N/S R 53E E Nye County
PERMIT NO. (Issued by Water Resources) 29-191-18 (Parcel No.) Desert Hills (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	2	2
Grey Calache		2	10	8
White Calache		10	16	6
Light Brown Clay		16	28	12
Brown Calache		28	30	2
brown calache		30	59	29
brown calache		59	87	28
brown clay		87	90	3
brown clay	x	90	127	37
brown calache	x	127	159	32
brown calache	x	159	168	9
light brown calache	x	168	177	9
ght brown calache	x	177	185	8

DCNR/DWR Received FEB 13 1998 LAS VEGAS OFFICE

Date started 2/5/98 , 19__
Date completed 2/5/98 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
.5	na	.50

8. WELL CONSTRUCTION
Depth Drilled 185 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 7/8	Inches	0	Feet	185	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.28	0	185

Perforations:
Type perforation Saw Cut
Size perforation .188
From 145 feet to 185 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 185 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. (Contractor)
Address 2301 Winery Road, Suite 2 (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources the on-site driller 2086
Signed Larry Strickland (By driller performing actual drilling on-site or contractor)
Date 2-11-98