WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70480
Permit No.
Basin 103

NOTICE OF INTENT NO. 9874

1. OWNER Ron & Micheal Dykstra
MAILING ADDRESS
ADDRESS AT WELL LOCATION 18 Yhuanna
Hand House NV. 89706

2. LOCATION SE ¼ SE ¼ Sec. 29 T. 16 N/S R. 21 E. Lyon County
PERMIT NO. (Issued by Water Resources) A-063-06 (Parcel No.) Hand House (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☑ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Existing 8" Well		6	75	75
Brown Clay		75	90	15
Small Sands and Gravels		90	135	45
Large Coarse Gravels xxx		135	160	25
Ran 6 5/8 Liner Pipe				
From 55' to 160'				

RECEIVED 98 FEB 11 AM 11:01 STATE ENGINEER'S OFFICE

Date started 1-30, 1998
Date completed 1-31, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	40	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 85 Feet Depth Cased 105 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7 7/8 Inches		75 Feet	160 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.1188	55	160

Perforations:
Type perforation Mill Slot
Size perforation 3x3/32
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal N/A
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling (Contractor)
Address 20 Kit Kat Dr. (Contractor)
Carson City NV. 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack (By driller performing actual drilling on site or contractor)
Date 2-1-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627