WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70483
Permit No.
Basin 85

NOTICE OF INTENT NO. 35395

1. OWNER Browning Construction
MAILING ADDRESS 5515 Wedekind Road
Sparks, NEV 89431

ADDRESS AT WELL LOCATION 565 Capistrano Circle
Sparks, NEV 89436

2. LOCATION SW ¼ SW ¼ Sec. 18 T. 21 N/S R. 21 EAST WASHOE County

PERMIT NO. (Issued by Water Resources) Parcel No. 076-360-81 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
White fine sand		0	20	20
Clear & white				
quartz		20	60	40
White clay		60	75	15
White granite		75	100	25
White clay		100	120	20
Black & white				
granite		120	250	130
Weathered granite				
with white clay		250	280	30
Brown clay		280	295	15
Weathered granite		295	300	5
Black & white				
granite		300	415	115
Black & white				
granite fractured		415	420	5
Black & white				
granite hard		420	460	40
Black & white				
granite fractured		460	465	5
Black & white				
granite hard		465	500	35
Fractured weathered				
granite	X	500	575	75
T.D. 575'				

Date started December 22, 19 97
Date completed December 31, 19 97

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 575 Feet Depth Cased 575 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	50 Feet
8 3/4 Inches		50 Feet	575 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	.188	+1½	575

Perforations:
Type perforation Factory Sawed
Size perforation 3/32 x 3
From 535 feet to 555 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 575 feet to 50 feet

9. WATER LEVEL
Static water level 420 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service Inc. (Contractor)
Address P.O. Box 60130 (Contractor)
Reno, NEVADA 89506

Nevada contractor's license number issued by the State Contractor's Board 35387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066

Signed Nancy Welch (By driller performing actual drilling on site or contractor)
Date January 7, 1998

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627