

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 70485
 Permit No. 101
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37693

1. OWNER Skip Hitchcock ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 1830 4925 Reno Hwy, Fallon, NV 89406
Fallon, NV 89406

2. LOCATION SE 1/4 NE 1/4 Sec. 29 T 19N N/S R 28E E Churchill County
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. 008-473-05 Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____

4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|-----------------|--------------|------|-----|-----------|
| Brown Sand | | 0 | 5 | 5 |
| Brown Clay | | 5 | 10 | 5 |
| Brown Sand | | 10 | 15 | 5 |
| Brown Clay | | 15 | 18 | 3 |
| Brown Sand | | 18 | 30 | 12 |
| Fine Green Sand | | 30 | 50 | 20 |
| Gray Sand | | 50 | 75 | 25 |
| Brown Clay | | 75 | 78 | 3 |
| Brown Sand | | 78 | 94 | 16 |
| Fine Gray Sand | | 94 | 110 | 16 |
| Gray Clay | | 110 | 130 | 20 |
| Gray Sand | | 130 | 155 | 25 |
| Brown Clay | | 155 | 157 | 2 |
| Brown Sand | | 157 | 164 | 7 |
| Brown Clay | | 164 | 166 | 2 |
| Brown Sand | X | 166 | 174 | 8 |

8. WELL CONSTRUCTION
 Depth Drilled 174 Feet Depth Cased 174 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 174 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 | 3.92 | .258 | 0 | 174 |

Perforations:
 Type perforation Saw Cut
 Size perforation 1/8
 From 170 feet to 173 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 100
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 174 feet

9. WATER LEVEL
 Static water level 27 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling, Inc. Contractor

Date started 1/27/98 _____ 19____
 Date completed 1/27/98 _____ 19____

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | | | |

Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources to the on-site driller 1753
 Signed _____ By driller performing actual drilling on-site or contractor
 Date 2-17-98