WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70491
Permit No. 34528
Basin 99

NOTICE OF INTENT NO. 34528

1. OWNER Donald Reinier
MAILING ADDRESS 1025 Stewart St.
Reno, NV 89502

ADDRESS AT WELL LOCATION 355 Appaloosa Circle
Reno, NV 89506

2. LOCATION SW ¼ SW ¼ Sec. 9 4 T. 23 N/S R. 18 E. Washoe County
PERMIT NO. 006029 (Issued by Water Resources) 078-221-25 (Parcel No.) Rancho Haven (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy top soil		0	3	
Brown fine sand		3	40	
Brown dg with clay		40	121	
Broken rock and granite		121	165	
~~Brown~~		~~165~~	~~207~~	
Firm DG Brown		165	207	
Brown broken granite		207	233	
Brown dg		233	270	
White clean broken granite.		270	325	

Date started 12/17, 19 97
Date completed 12/22, 19 97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 325 Feet Depth Cased 325 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	325 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		.188	0	325

Perforations:
Type perforation Factory
Size perforation 1/8
From 305 feet to 325 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 56
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 103 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Turner Drilling & Pump (Contractor)
Address 472-205 JOhnstonville Rd (Contractor)
Susanville, ca 96130

Nevada contractor's license number issued by the State Contractor's Board 41661
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2037

Signed Frand Turner (By driller performing actual drilling on site or contractor)
Date 12/30/97

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627