

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16558

1. OWNER LVP ADDRESS AT WELL LOCATION On Indias rd  
 MAILING ADDRESS 4420 S Decatur Tuam  
LU NV  
 2. LOCATION SE 1/4 NE 1/4 Sec 17 T 21 R 60 E Clark County  
 PERMIT NO. DW 1078 161-17-701-001 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE dewater WELL TYPE  
 Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Municipal/Industrial  Monitor  Stock  Air  Other Bucket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	6"	6"
Type 2		6"	2'	1 1/2'
Sandy dirt		2	6	4
Sandy		6	12	6
Fine-mesh sand w/silt		12	26	14
Clay w/s.s.		26	32	6
Clay		32	35	3

8. WELL CONSTRUCTION  
 Depth Drilled 35 Feet Depth Cased 35 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 24 Inches To 35 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	PVC	5/16	0	35

Perforations:  
 Type perforation slot  
 Size perforation 003  
 From 15 feet to 35 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 0 feet to 35 feet

9. WATER LEVEL  
 Static water level 9 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60 °F Quality H<sub>2</sub>O

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GD Contractor  
 Address 536 E Mainland Contractor  
Ontario CA  
 Nevada contractor's license number 36246  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1908  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 1-26-98

Date started 1-7-98  
 Date completed 1-7-98

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			