WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70577
Permit No.
Basin 212

NOTICE OF INTENT NO. 17442

1. OWNER Melvin Shapiro/Al Phillips
MAILING ADDRESS 3250 Ali Baba Lane
Las Vegas, Nevada 89118

ADDRESS AT WELL LOCATION 3620 West Sahara Avenue
Las Vegas, Nevada

2. LOCATION SW ¼ SW ¼ Sec. 5 T. 21 N/S R. 61 E. Clark County
PERMIT NO. Issued by Water Resources
Parcel No. 162-05-402-004
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pavement/Gravel Base		0	2	
Brown silty SAND w/ clay, very fine to med. sand		2	10	
Same		5	10	
Caliche		10	11	
Yellowish brown Sand w/ silt, very fine sand, moist, dense		11	20	
Same but wet		20	23	
Brown sand, w/silt		23	27	
Brown silty sand, very fine to med.		27	28	
Caliche		28	34	
Brown silty sand, dense to hard, moderately cemented		34	40	
Brown silty sand, wet, dense to hard		40	54	
Caliche		54	56	
Brown silty sand, very fine to med, trace very fine gravel		56	67	

Date started 1/14/98, 19
Date completed 1/14/98, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 67 Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	67 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	—	—	0	60

Perforations:
Type perforation Sch 40
Size perforation .010
From 60 feet to 67 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55' feet to 67' feet

9. WATER LEVEL
Static water level 12.25 feet below land surface
Artesian flow / G.P.M. / P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THEVERDE COMPANIES, INC (Contractor)
Address 3121 SOUTH PARK (Contractor)
TEMPE, ARIZONA 85282
Nevada contractor's license number issued by the State Contractor's Board 41809
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M02070
Signed John Manley
By driller performing actual drilling on site or contractor
Date 1-15-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627