WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70655
Permit No.
Basin 93

NOTICE OF INTENT NO. 37096

1. OWNER CODY MORI
MAILING ADDRESS 522 N. Hwy 395
Carson City, Nevada 89704

ADDRESS AT WELL LOCATION
15700 Elkhorn ~~Road~~ Lane
Reno, Nevada 89506

2. LOCATION NE SW ¼ NW ¼ Sec. 23 T 22N N/S R19 E Washoe County
PERMIT NO. (Issued by Water Resources) 079-470-71 (Parcel No.) Antelope Valley Ranchettes, Unit 1 Part 3 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	3	2
Brown fine sand		3	27	24
Brown clays with decomposed granite sands		27	30	3
Brown sandy clays		30	63	33
Soft zone, decomposed sands		63	67	4
Brown sandy clays		67	111	44
Soft zone, brown sands	X	111	118	7
Brown clay		118	122	4
Brown sands with small clay streaks	X	122	140	18

Date started 2-10-98, 19
Date completed 2-12-98, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	140 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	140

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 95 feet to 135 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 foot
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 73 feet below land surface
Artesian flow G.P.M. 20+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed Gary L. Helman (By driller performing actual drilling on site or contractor)
Date February 16, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627