WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 706560
Permit No. 85
Basin

NOTICE OF INTENT NO. 37751

1. OWNER Justin Bonca
MAILING ADDRESS 265 Bradhart Ave.
Reno, Nevada 89509

ADDRESS AT WELL LOCATION Capistrano Circle

2. LOCATION NW ¼ SW ¼ Sec. 18 T. 21 N/S R. 21 EAST WASHOE County
PERMIT NO. (Issued by Water Resources) 076-360-73 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
White & brown fine sand		0	5	5
Brown D.G.		5	15	10
Gray clay		15	32	17
Brown clay		32	40	8
Brown clay with white quartz		40	50	10
Brown clay		50	140	90
Gray clay		140	175	35
Brown clay		175	210	35
Black & white granite		210	290	80
Weathered granite		290	375	85
Black & white granite		375	500	125
Fractured weathered granite		500	575	75
T.D. 575'				

Date started January 23, 1998
Date completed January 28, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		2 HRS.

8. WELL CONSTRUCTION
Depth Drilled 575 Feet Depth Cased 575 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	50 Feet
8 3/4	Inches	50 Feet	575 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	.188	+1½	575

Perforations:
Type perforation Factory sawed
Size perforation 3/32x3
From 535 feet to 575 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 575 feet to 50 feet

9. WATER LEVEL
Static water level 470 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service Inc. (Contractor)
Address P.O. Box 60130 (Contractor)
Reno, Nevada 89506

Nevada contractor's license number issued by the State Contractor's Board 35387-A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066

Signed Larry Welch (By driller performing actual drilling on site or contractor)
Date Feb 16, 1998

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627