WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 70659
Permit No. 64601
Basin 101

NOTICE OF INTENT NO. 37897

1. OWNER Skip Hitchcock
MAILING ADDRESS P.O. Box 1830
Fallon, NV 89407

ADDRESS AT WELL LOCATION
4901 Reno Hwy, Fallon, Nv 89406

2. LOCATION ~~SE~~ SW 1/4 ~~NE~~ NW 1/4 Sec. 29 28 T 19N N/S R 28E E Churchill County
PERMIT NO. ~~2581~~ 64601 Issued by Water Resources
8-473-04 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial (Commercial) ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gray Clay		100	130	30
Gray Sand		130	150	20
Brown Clay		150	152	2
Brown Sand		152	157	5
Brown Clay		157	159	2
Brown Sand	x	159	165	6

Date started 1/6/98, 19__
Date completed 1/8/98, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 165 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8.5 Inches		100 Feet	165 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5 9/16	3.91	.258	0	165

Perforations:
Type perforation Well Screen
Size perforation .030
From 160 feet to 165 feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 165 feet

9. WATER LEVEL
Static water level 27 feet below land surface
Artesian flow ___ G.P.M. ___ P.S.I.
Water temperature Cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources the on-site driller 1753

Signed Wayne Parsons
By driller performing actual drilling on-site or contractor
Date 2-17-98